



"EQUIPMENT FOR GROUTING"

GROUT PUMPS & MIXERS • ACCESSORIES • GROUTING SYSTEMS • TECHNICAL ASSISTANCE

September 26, 1994

Irv Kaufman  
Kaufman Products Inc.  
3811 Curtis Ave.  
Baltimore, MD 21226

Re: Sure Grout

The following is our test report on the pumping characteristics of the Sure Grout as tested here at ChemGrout on September 20, 1994. We appreciate very much your confidence in our equipment and the opportunity to be of service.

The Sure Grout mixed quickly and thoroughly to smooth, creamy consistency, and it was pumped without difficulty.

Conditions: Inside warehouse temp. 68 Degrees F.

Equipment Used: CG-550P Grout pump & mixer, and a 1" X 50' Grout hose.

Mixing Water Temperature: 68 Degrees F.

Sure Grout: 4 bags were added to 16 quarts total water in the mixer. With mixer blades running at about 60-75 RPM a creamy, smooth, lump-free consistency was observed about 30 seconds after the last bag was added.

The batch was pumped and recirculated for 5 minutes, then allowed to sit in the hopper without movement for 5 minutes. Pumping was resumed without problems.

No discoloration or separation was observed. The material appeared to stay in suspension without significant settlement of aggregate.

ChemGrout considers this product to be "excellent" for mixing and pumping through the CG-550P.

Yours truly,

Marvin Hansen  
ChemGrout, Inc.